

CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The product:

*Seismic Transmitters ST5484E and ST5491E
(all configurations)*

Manufactured by:

*Metrix Instruments Co.
8824 Fallbrook Dr. Houston, TX 77064
United States of America*

suitable for the following safety function(s):

Provides a 4-20mA DC signal output proportional to the vibration amplitude of rotating equipment portion where installed.

has been assessed per the relevant requirements of

IEC 61508:2010 Parts 1 to 7

and meets the requirements providing the following:

Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1_s.

SC 2

Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1_H.

**Type
A**

Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

**See
page
2**

The architectural constraints and the effects of random failures (PFH / PFD_{AVG}) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

BYHON

BYHON Certification Director:



Rosati Francesco

CERTIFICATE No:
MTXI-5484E-ENS-E01
Revision: A

Issued:
July 31st, 2019

Valid until:
July 30th, 2022

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

BYHON
SIL ✓

ID.N° 500719E01N

The design of each Safety Instrumented Function (SIF) shall meet the requirements listed in the reference standards that shall be selected by taking into account the specific application. Specific activities necessary to investigate and reach a judgment on the adequacy of the functional safety achieved by the E/E/PE safety-related system or compliant items (elements/subsystems) has been conducted by an independent assessor.

The following failure rates data shall be used to the PFH / PFD_{AVG} estimation, taking into consideration all parameters such as redundancy, architectural constraints, diagnostic capability, also introduced by the whole system, including the considerations about the proof test and its effectiveness, mean time of restoration, up to the maintenance capability and its minimum characteristics.

Failure rate for Seismic Transmitters ST5484E and ST5491E– All configurations

λ_{SU}	λ_{SD}	λ_{DU}	λ_{DD}	λ_{RES}
94	0	117	114	640

Note:

- All failure rates are in FIT (Failure In Time 1 FIT = 1 failure / 10⁹ hours).
- The λ_{RES} (RESIDUAL) failure rates includes the NO PART and NO EFFECT failure rates.
- The prescriptions contained in the safety manual related to failure rates of DIPV and TIPV common and redundant part shall be followed.

The prescriptions contained in the safety manual QP064-42 shall be followed.

CERTIFICATE NO:
MTXI-5484E-ENS-E01

Revision: A

Issued:
July 31st, 2019

Valid until:
July 30th, 2022

The Functional Safety
Assessment report no.

19-MTX-5484E-FSA-01

dated:
July 29th, 2019

is an integral part of this
certificate

